

Republic of the Philippines
SURIGAO METROPOLITAN WATER DISTRICT
 Km. 2, National Highway, 8400 Surigao City
 TeleFax No. (086) 826-0269

Document Code No.		
FR-WR-WGDEWS-100-1		
Page No.	Expiry Date	Page No.
00	09.08.18	1 of 1

WATER RESOURCES DIVISION
Water Quality Section

WATER EXAMINATION
 DOH Accreditation No. 16-01-17-LW-1

Sample Source : Bottled Water Sample Labeled " Deep Well "
 Location : Purok Tisa, Salvacion , Tandag City c/o Vallescas, Norma Res. (TWD)
 Sample Laboratory Nos. : B-C-1-19-018
 Submitted by : Johncent R. Espinoza
 Contact Nos. : N/A
 Date and Time of
 Collection : Jan. 21, 2019 – 11:23 PM
 Receipt : Jan. 22, 2019 – 9:30 AM
 Examination : Jan. 22, 2019 – 4:00 PM
 Sample Preservation : NO
 Chlorine Residual : 0.4
 Sample Treated : YES

RESULTS OF THE BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

EXAMINATION	RESULT	PNSDW 2007
COLIFORM INDEX TEST (Multiple Tube Fermentation Technique)		
Total Coliform Test No. of positive Tube/s after 48 hours MPN per 100 ml	0 TUBE <1.1	0 TUBE <1.1
Fecal Coliform Test No. of Positive Tube/s after 24 hours MPN per 100 ml	0 TUBE <1.1	0 TUBE <1.1
BACTERIAL COUNT (Heterotrophic Plate Count)		
No. of colonies after 48 hours CFU per ml	0 CFU/mL	< 500 CFU/mL

Remarks:

1. Upon examination, the water sample gave **NEGATIVE** result for total coliform, **NEGATIVE** result for fecal coliform organisms and gave a bacterial count **0 cfu/mL for HPC**. Thus, the water sample from Purok Tisa, Salvacion, Tandag City c/o Vallescas, Norma Res. (TWD), **PASSED PNSDW**.

2. Results projected refer only to the particular sample submitted.

Analyzed by:


MARYSOL L. BENITEZ, RMT
 Medical Technologist
 PRC# 0031495

Recommending Approval:


ENGR. LIBETH T. FILOTEO
 Head of the Laboratory // DM Water Resources
 PRC# 0017170

Approved by:


ENGR. BENJAMIN R. ENSOMO JR.
 General Manager

Republic of the Philippines
SURIGAO METROPOLITAN WATER DISTRICT
 Km. 2, National Highway, 8400 Surigao City
 TeleFax No.:(086) 826-0269

Document Code No		
FR-WR-WGDEWS-100-1		
Revision No.	Effective Date	Page No.
00	09.08.18	1 of 1

WATER RESOURCES DIVISION
Water Quality Section

WATER EXAMINATION
 DOH Accreditation No. 16-01-17-LW-1

Sample Source : Bottled Water Sample Labeled " Deep Well "
 Location : Tello St. Bongtud c/o.Tubo, Evelito Res. (TWD)
 Sample Laboratory Nos. : B-C-1-19-017
 Submitted by : Johncent R. Espinoza
 Contact Nos. : N/A
 Date and Time of
 Collection : Jan. 21, 2019 – 11:15 PM
 Receipt : Jan. 22, 2019 – 9:30 AM
 Examination : Jan. 22, 2019 – 3:50 PM
 Sample Preservation : NO
 Chlorine Residual : 0.3
 Sample Treated : YES

RESULTS OF THE BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE


EXAMINATION	RESULT	PNSDW 2007
COLIFORM INDEX TEST (Multiple Tube Fermentation Technique)		
Total Coliform Test No. of positive Tube/s after 48 hours MPN per 100 ml	0 TUBE <1.1	0 TUBE <1.1
Fecal Coliform Test No. of Positive Tube/s after 24 hours MPN per 100 ml	0 TUBE <1.1	0 TUBE <1.1
BACTERIAL COUNT (Heterotrophic Plate Count)		
No. of colonies after 48 hours CFU per ml	9 CFU/mL	< 500 CFU/mL

Remarks:


1. Upon examination, the water sample gave **NEGATIVE** result for total coliform, **NEGATIVE** result for fecal coliform organisms and gave a bacterial count **9 cfu/mL for HPC**. Thus, the water sample from **Tello St. Bongtud c/o.Tubo, Evelito Res. (TWD)**, **PASSED PNSDW**.

2. Results projected refer only to the particular sample submitted.

Analyzed by:


MARYSOD L. BENITEZ, RMT
 Medical Technologist
 PRC# 0031495

Recommending Approval:


ENGR. LILIBETH T. FLOTEO
 Head of the Laboratory / DM Water Resources
 PRC# 0017170

Approved by:


ENGR. BENJAMIN R. ENSOMO JR.
 General Manager

Republic of the Philippines
SURIGAO METROPOLITAN WATER DISTRICT
 Km. 2, National Highway, 8400 Surigao City
 TeleFax No. (086) 826-0269

Document Code No.		
FR-WR-WGDEWS-100-1		
Revised No.	Effective Date	Page No.
00	09.08.18	1 of 1

WATER RESOURCES DIVISION
Water Quality Section

WATER EXAMINATION
 DOH Accreditation No. 16-21-17-LW-1

Sample Source : Bottled Water Sample Labeled " Deep Well "
 Location : Purok Aguinaldo, Buenavista , c/o Rodriguez, Adelfa Res. (TWD)
 Sample Laboratory Nos. : B-C-1-19-016
 Submitted by : Johncent R. Espinoza
 Contact Nos. : N/A
 Date and Time of
 Collection : Jan. 21, 2019 – 11:01 PM
 Receipt : Jan. 22, 2019 – 9:30 AM
 Examination : Jan. 22, 2019 – 3:40 PM
 Sample Preservation : NO
 Chlorine Residual : 0.5
 Sample Treated : YES

RESULTS OF THE BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

EXAMINATION	RESULT	PNSDW 2007
COLIFORM INDEX TEST (Multiple Tube Fermentation Technique)		
Total Coliform Test No. of positive Tube/s after 48 hours MPN per 100 ml	0 TUBE <1.1	0 TUBE <1.1
Fecal Coliform Test No. of Positive Tube/s after 24 hours MPN per 100 ml	0 TUBE <1.1	0 TUBE <1.1
BACTERIAL COUNT (Heterotrophic Plate Count)		
No. of colonies after 48 hours CFU per ml	0 CFU/ml	< 500 CFU/mL

Remarks:

1. Upon examination, the water sample gave **NEGATIVE** result for total coliform, **NEGATIVE** result for fecal coliform organisms and gave a bacterial count **0 cfu/mL for HPC**. Thus, the water sample from **Purok Aguinaldo, Buenavista, c/o Rodriguez, Adelfa Res. (TWD), PASSED PNSDW.**

2. Results projected refer only to the particular sample submitted.

Analyzed by:


MARYSOL L. BENITEZ, RMT
 Medical Technologist
 PRC# 0031495

Recommending Approval:


ENGR. LILIBETH T. FILOTEO
 Head of the Laboratory / DM Water Resources
 PRC# 0017170

Approved by:


ENGR. BENJAMIN R. ENSOMO JR.
 General Manager

Republic of the Philippines
SURIGAO METROPOLITAN WATER DISTRICT
 Km. 2, National Highway, 8400 Surigao City
 TeleFax No.-(086) 826-0269

Document Code No.		
FR-WR-WGDEWS-100-1		
Revision No.	Effective Date	Page No.
00	09.08.18	1 of 1

WATER RESOURCES DIVISION
Water Quality Section

WATER EXAMINATION
 DOH Accreditation No. 16-01-17-LW-1

Sample Source : Bottled Water Sample Labeled " Deep Well "
 Location : Emeral St. Mabua , c/o Furgosa, Alcher S. Res. (TWD)
 Sample Laboratory Nos. : B-C-1-19-015
 Submitted by : Johncent R. Espinoza
 Contact Nos. : N/A
 Date and Time of
 Collection : Jan. 21, 2019 – 10:54 PM
 Receipt : Jan. 22, 2019 – 9:30 AM
 Examination : Jan. 22, 2019 – 3:30 PM
 Sample Preservation : NO
 Chlorine Residual : 0.3
 Sample Treated : YES

RESULTS OF THE BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

EXAMINATION	RESULT	PNSDW 2007
COLIFORM INDEX TEST (Multiple Tube Fermentation Technique)		
Total Coliform Test No. of positive Tube/s after 48 hours MPN per 100 ml	0 TUBE <1.1	0 TUBE <1.1
Fecal Coliform Test No. of Positive Tube/s after 24 hours MPN per 100 ml	0 TUBE <1.1	0 TUBE <1.1
BACTERIAL COUNT (Heterotrophic Plate Count)		
No. of colonies after 48 hours CFU per ml	14 CFU/mL	< 500 CFU/mL

Remarks:

1. Upon examination, the water sample gave **NEGATIVE** result for total coliform, **NEGATIVE** result for fecal coliform organisms and gave a bacterial count **14 cfu/mL for HPC**. Thus, the water sample from **Emeral St. Mabua, c/o Furgosa, Alcher S. Res. (TWD)**, **PASSED PNSDW**.

2. Results projected refer only to the particular sample submitted.


Analyzed by:


MARYSOL L. BENITEZ, RMT
 Medical Technologist
 PRC# 0031495

Recommending Approval:


ENGR. LILIBETH T. FILOTEO
 Head of the Laboratory / DM Water Resources
 PRC# 0017170

Approved by:


ENGR. BENJAMIN R. ENSOMO JR.
 General Manager

Republic of the Philippines
SURIGAO METROPOLITAN WATER DISTRICT
 Km. 2, National Highway, 8400 Surigao City
 TeleFax No.:(086) 826-0269

Document Code No		
FR-WR-WGDEWS-100-1		
Revised No.	Effective Date	Page No.
00	09.08.18	1 of 1

WATER RESOURCES DIVISION
Water Quality Section

WATER EXAMINATION
 DOH Accreditation No. 16-01-17-LW-1

Sample Source : Bottled Water Sample Labeled " Deep Well "

Location : Purak Guava, Awasian, c/o Laro Ruel D. Res. (TWD)

Sample Laboratory Nos. : B-C-1-19-014

Submitted by : Johncent R. Espinoza

Contact Nos. : N/A

Date and Time of

Collection : Jan. 21, 2019 – 10:43 PM

Receipt : Jan. 22, 2019 – 9:30 AM

Examination : Jan. 22, 2019 – 3:20 PM

Sample Preservation : NO

Chlorine Residual : 0.3

Sample Treated : YES

RESULTS OF THE BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

EXAMINATION	RESULT	PNSDW 2007
COLIFORM INDEX TEST (Multiple Tube Fermentation Technique)		
Total Coliform Test No. of positive Tube/s after 48 hours MPN per 100 ml	0 TUBE <1.1	0 TUBE <1.1
Fecal Coliform Test No. of Positive Tube/s after 24 hours MPN per 100 ml	0 TUBE <1.1	0 TUBE <1.1
BACTERIAL COUNT (Heterotrophic Plate Count)		
No. of colonies after 48 hours CFU per ml	2 CFU/ml	< 500 CFU/ml

Remarks:

1. Upon examination, the water sample gave **NEGATIVE** result for total coliform, **NEGATIVE** result for fecal coliform organisms and gave a bacterial count **2 cfu/mL for HPC**. Thus, the water sample from Purak Guava, Awasian, c/o Laro Ruel D. Res. (TWD), **PASSED PNSDW**.

2. Results projected refer only to the particular sample submitted.


Analyzed by:


MARYSOL L. BENITEZ, RMT
 Medical Technologist
 PRC# 0031495

Recommending Approval:


ENGR. LILIBETH T. FILOTEO
 Head of the Laboratory / DM Water Resources
 PRC# 0017170

Approved by:


ENGR. BENJAMIN R. ENSOMO JR.
 General Manager

Republic of the Philippines
SURIGAO METROPOLITAN WATER DISTRICT
 Km. 2, National Highway, 8400 Surigao City
 TeleFax No. (086) 826-0269

Document Code No.		
FR-WR-WGDEWS-100-1		
Revised No.	Effective Date	Page No.
00	09.08.18	1 of 1

WATER RESOURCES DIVISION
Water Quality Section

WATER EXAMINATION
 DOH Accreditation No. 16-01-17-LW-1

Sample Source : Bottled Water Sample Labeled " Deep Well "

Location : Purok Kalipayan, Quezon, c/o Perez, Leonardo A. Res. (TWD)

Sample Laboratory Nos. : B-C-1-19-013

Submitted by : Johncent R. Espinoza

Contact Nos. : N/A

Date and Time of

Collection : Jan. 21, 2019 – 10:39 PM

Receipt : Jan. 22, 2019 – 9:30 AM

Examination : Jan. 22, 2019 – 3:10 PM

Sample Preservation : NO

Chlorine Residual : 0.4

Sample Treated : YES

RESULTS OF THE BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE


EXAMINATION	RESULT	PNSDW 2007
COLIFORM INDEX TEST (Multiple Tube Fermentation Technique)		
Total Coliform Test No. of positive Tube/s after 48 hours MPN per 100 ml	0 TUBE <1.1	0 TUBE <1.1
Fecal Coliform Test No. of Positive Tube/s after 24 hours MPN per 100 ml	0 TUBE <1.1	0 TUBE <1.1
BACTERIAL COUNT (Heterotrophic Plate Count)		
No. of colonies after 48 hours CFU per ml	3 CFU/mL	< 500 CFU/mL

Remarks:

1. Upon examination, the water sample gave **NEGATIVE** result for total coliform, **NEGATIVE** result for fecal coliform organisms and gave a bacterial count **3 cfu/mL for HPC**. Thus, the water sample from **Purok Kalipayan, Quezon, c/o Perez, Leonardo A. Res. (TWD)**, **PASSED PNSDW**.

2. Results projected refer only to the particular sample submitted.

Analyzed by:


MARYSOLL BENITEZ RMT
 Medical Technologist
 PRC# 0031495

Recommending Approval:


ENGR. LILIBETH T. FILOTEO
 Head of the Laboratory / DM Water Resources
 PRC# 0017170

Approved by:


ENGR. BENJAMIN R. ENSOMO JR.
 General Manager

